United Kingdom Partners | Where To Buy |





PRODUCT NUMBER: 2091922 ELECTROSOFT LATEX RE -

Class 2

For electrical work with a maximum voltage of 17000 volts.

Honeywell

Overview

Reference Number

2091922

Product Type

Gloves

Range

Electrical Protection

Line

Latex

Brand

Honeywell

Brand formerly known as

ELECTROSOFT

Industry

Administration

Product Use

For electrical work with a maximum voltage of 17000 volts. To be used with leather protectors for mechanical protection.

Features & Benefits

Feature

Insulating natural latex rubber glove Bi-color: black inside, beige outside

Rolled edge RC Category Class 2

Proof test voltage: 20 000 volts

Benefit

COMFORT

Its anatomical shape makes it easier to slip the glove on and off.

Product appreciated for its long last and precision.

RESISTANCE

ELECTROSOFT LATEX RE - Class 2 - 2091922

The natural latex base offers high dielectric characteristics.

Its two-toned composition, with its beige exterior/black interior, indicates wear on the whole of the glove. Its thickness provides good dexterity while offering protection up to 17,000 volts.

SAFETY

To be used with leather protectors for mechanical protection.

Technical Description

Description

CE CATEGORY : III Irreversible risks In accordance with standards : EN 60903-2003

CEI 903-2002

CHARACTERISTICS:

Insulating natural latex rubber glove Bi-color : black inside, beige outside

Rolled edge RC Category

Proof test voltage: 20 000 volts

Product Technology

Dipped Gloves

Glove/liner color

Beige and black

Length

41 cm

Thickness

2,3 mm

Harmlessness

In conformity with European standards

Dexterity

Class 2

Sizes

8 to 11

Packaging Label

Tagging

CE HONEYWELL 2091922 XX EN 60903-2003 CEI 903-2002

Certifications

EU Category PPE

3

EU Certification

EC Attestation

Additional Information

User Manual

User Information Sheet

On the polybag

ELECTROSOFT LATEX RE - Class 2 - 2091922

Maintenance

Life Cycle

Gloves that are used frequently should be tested at intervals less than 6 month.

Gloves that are used only occasionally should be tested after each use and, in any case, at intervals of not more than 12 months.

Gloves held in stock should be retested at intervals not exceeding 12 months.

Storage Information

Store in original packaging (Opaque and antiUV packaging used for protection and instructions for use).

Do not compact or fold.

Do not expose to heat sources (sunlight, radiators, artificial light).

Store between 10°C and 21°C.

Care Instructions

Inpsection: Before each use, carry out a visual inspection and check the glove inflation. Any puncture or perforation makes the gloves unusable.

Precautions: Do not expose to solvents or chemicals that may cause deterioration. Do not use the glove when damp.

Cleaning: use water and soap. Dry below 65°C with ambient humidity.

© Honeywell International Inc.