Honeywell | Safety Products

United Kingdom Partners Where To Buy



PRODUCT NUMBER: 2091932 ELECTROSOFT LATEX RE -Class 3

For electrical work with a maximum voltage of 26 500 volts.

Honeywell

Overview

Reference Number 2091932

Product Type Gloves

Range Electrical Protection

Line Latex

Brand Honeywell

Brand formerly known as ELECTROSOFT

Industry

Administration

Product Use

For electrical work with a maximum voltage of 26 500 volts. To be used with leather protectors for mechanical protection.

Features & Benefits

Feature

Insulating natural rubber glove Bi-color : black inside, beige outside Rolled edge Proof test voltage : 30 000 volts

Benefit

COMFORT

Its anatomical shape makes it easier to slip the glove on and off. Product appreciated for its long life and precision.

RESISTANCE

The natural latex base offers high dielectric characteristics. Its two-toned composition, with its black interior/beige exterior, indicates wear on the whole of the glove.

> Page 1 Of 3 © Honeywell International Inc.

Q

ELECTROSOFT LATEX RE - Class 3 - 2091932

Its thickness provides good dexterity while offering protection up to 26,500 volts.

SAFETY

To be used with leather protectors for mechanical protection.

Technical Description

Description

CE CATEGORY : III Irreversible risks In accordance with standards : EN 60903-2003 CEI 903-2002

CHARACTERISTICS : Insulating natural rubber glove Bi-color : black inside, beige outside Rolled edge Proof test voltage : 30 000 volts

Product Technology Dipped Gloves

Glove/liner color Beige et noir

Coating Type Latex

Length 41 cm

Thickness 2,9 mm

Harmlessness

In conformity with European standards

Sizes 9 to 11

Packaging Label

Tagging

CE HONEYWELL 2091932 XX EN 60903-2003 CEI 903-2002

Certifications

EU Category PPE

EU Certification EC Attestation

Additional Information

User Manual User Information Sheet On the polybag

Maintenance

ELECTROSOFT LATEX RE - Class 3 - 2091932

Life Cycle

Gloves that are used frequently should be tested at intervals less than 6 month.

Gloves that are used only occasionally should be tested after each use and, in any case, at intervals of not more than 12 months.

Gloves held in stock should be retested at intervals not exceeding 12 months.

Storage Information

Store in original packaging (Opaque and antiUV packaging used for protection and instructions for use).

Do not compact or fold.

Do not expose to heat sources (sunlight, radiators, artificial light).

Store between 10°C and 21°C.

Care Instructions

Inpsection : Before each use, carry out a visual inspection and check the glove inflation. Any puncture or perforation makes the gloves unusable.

Precautions : Do not expose to solvents or chemicals that may cause deterioration. Do not use the glove when damp.

Cleaning : use water and soap. Dry below 65°C with ambient humidity.

Honeywell International Inc.